

Building: Fifteenth Avenue, 557 15th Ave.

Sampling Date: 7/23/2016

Red highlighting indicates a fixture's lead measurement was both elevated and a drinking water source.

Blue highlighting indicates a fixture's lead measurement was elevated, but was not a drinking water source.

Summary

Number of samples taken	39
Number of samples >= 15.5ppb	11
Percent of samples >= 15.5ppb	28%

Number of drinking water samples taken	15
Number of drinking water samples taken >= 15.5ppb	2
Percent of drinking water samples taken >= 15.5ppb	13%

NPS Lead ID	Field ID	Description	Drinking Water	Result (ppb)	>=15.5 ppb
2	FFA BF BFL S1 UN07	Basement floor, Bathroom faucet - Location UN07, Fixture 1	No	27.6	Yes
3	FFA WC BFL S1 UN07	Basement floor, Water cooler - chill unit - Location UN07, Fixture 1	Yes	1.7	No
4	FFA BF BFL S1 UN04	Basement floor, Bathroom faucet - Location UN04, Fixture 1	No	64.0	Yes
5	FFA HS BFL N1 UN15	Basement floor, Hand sink - Location UN15, Fixture 1	No	67.5	Yes
6	FFA NS 1FL S1 100	1st floor, Nurse's office sink - Location 100, Fixture 1	Yes	16.6	Yes
7	FFA NS 1FL S1 100 FLUSH	1st floor, Nurse's office sink - Location 100, Fixture 1 (flushed prior to testing)	Yes	1.7	No
8	FFA WC 1FL S1 100H	1st floor, Water cooler - chill unit - Location 100H, Fixture 1	Yes	ND	No
9	FFA CF 1FL S1 105	1st floor, Classroom faucet - Location 105, Fixture 1	No	1.7	No
10	FFA CF 1FL S1 105 FLUSH	1st floor, Classroom faucet - Location 105, Fixture 1 (flushed prior to testing)	No	1.7	No
11	FFA HS 1FL S1 UN30	1st floor, Hand sink - Location UN30, Fixture 1	No	33.6	Yes
12	FFA BF 1FL W1 UN36	1st floor, Bathroom faucet - Location UN36, Fixture 1	No	0.8	No
13	FFA BF 1FL W5 UN37	1st floor, Bathroom faucet - Location UN37, Fixture 5	No	0.5	No
14	FFA WC 1FL W1 UN37H	1st floor, Water cooler - chill unit - Location UN37H, Fixture 1	Yes	0.2	No
15	FFA WC 1FL W2 UN37H	1st floor, Water cooler - chill unit - Location UN37H, Fixture 2	Yes	0.9	No
16	FFA WC 1FL W3 UN37H	1st floor, Water cooler - chill unit - Location UN37H, Fixture 3	Yes	0.3	No
17	FFA BF 1FL N1 UN44	1st floor, Bathroom faucet - Location UN44, Fixture 1	No	2.3	No
18	FFA HS 1FL N1 UN49	1st floor, Hand sink - Location UN49, Fixture 1	No	110.0	Yes
19	FFA BF 2FL N1 UN62	2nd floor, Bathroom faucet - Location UN62, Fixture 1	No	3.3	No
20	FFA BF 2FL WS GIRL	2nd floor, Bathroom faucet - Location GIRL, Fixture	No	1.1	No
21	FFA BF 2FL S1 UN57	2nd floor, Bathroom faucet - Location UN57, Fixture 1	No	1.0	No
22	FFA BF 2FL S1 UN52	2nd floor, Bathroom faucet - Location UN52, Fixture 1	No	55.3	Yes
23	FFA BF 3FL S1 UN65	3rd floor, Bathroom faucet - Location UN65, Fixture 1	No	14.0	No
24	FFA KC 3FL S1 UN71	3rd floor, Kitchen faucet, cold - Location UN71, Fixture 1	Yes	17.5	Yes
25	FFA BF 3FL N1 UN78	3rd floor, Bathroom faucet - Location UN78, Fixture 1	No	6.9	No
26	FFA HS 3FL N1 UN80	3rd floor, Hand sink - Location UN80, Fixture 1	No	15.2	No
27	FFA WC 1FL W2 UN37H FLUSH	1st floor, Water cooler - chill unit - Location UN37H, Fixture 2 (flushed prior to testing)	Yes	ND	No
28	FFA BF 2FL W1 MEN	2nd floor, Bathroom faucet - Location MEN, Fixture 1	No	1.4	No
29	FFA HS 2FL S1 206	2nd floor, Hand sink - Location 206, Fixture 1	No	75.6	Yes
30	FFA WC 2FL S1 200H	2nd floor, Water cooler - chill unit - Location 200H, Fixture 1	Yes	ND	No
31	FFA WC 1FL S1 100H FLUSH	1st floor, Water cooler - chill unit - Location 100H, Fixture 1 (flushed prior to testing)	Yes	ND	No

NPS Lead ID	Field ID	Description	Drinking Water	Result (ppb)	>=15.5 ppb
32	FFA WC 1FL W1 UN37H FLUSH	1st floor, Water cooler - chill unit - Location UN37H, Fixture 1 (flushed prior to testing)	Yes	ND	No
33	FFA WC BFL S1 UN07 FLUSH	Basement floor, Water cooler - chill unit - Location UN07, Fixture 1 (flushed prior to testing)	Yes	0.5	No
34	FFA WC 1FL W3 UN37H FLUSH	1st floor, Water cooler - chill unit - Location UN37H, Fixture 3 (flushed prior to testing)	Yes	ND	No
35	FFA HS 1FL N1 UN51	1st floor, Hand sink - Location UN51, Fixture 1	No	72.5	Yes
36	FFA SL 2FL N1 211	2nd floor, Science Lab - Location 211, Fixture 1	No	18.5	Yes
37	FFA BF 2FL S1 200A	2nd floor, Bathroom faucet - Location 200A, Fixture 1	No	7.1	No
38	FFA KC 3FL S1 UN71 FLUSH	3rd floor, Kitchen faucet, cold - Location UN71, Fixture 1 (flushed prior to testing)	Yes	0.9	No
39	FFA HS 3FL S1 UN75	3rd floor, Hand sink - Location UN75, Fixture 1	No	1.8	No
40	FFA BF BFL S1 UN07 FLUSH	Basement floor, Bathroom faucet - Location UN07, Fixture 1 (flushed prior to testing)	No	2.4	No