

August 21, 2024

Kamal Johnson
Senior Manager
Facilities Management Team
Uncommon Schools
100 Church Street, 9th Floor
New York, NY 10007

For distribution

RE: **Lead in Drinking Water Sampling
North Star Academy – 18 Washington Street**
18 Washington Street
Newark, NJ 07102
EL Project # 21-0021

Dear Mr. Johnson:

North Star Academy Schools are committed to protecting student, teacher, and staff health. To protect the North Star community and be in compliance with the Department of Education regulations, North Star Academy retained Environmental Logic, LLC (EL) to test the school's drinking water for lead.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, a plumbing profile for each of the buildings within the North Star Academy system was prepared. Through this effort, we identified and tested all drinking water and food preparation outlets. The US Environmental Protection Agency has established a lead in drinking water action level of 15 µg/l [ppb]. On July 19, 2024, EL collected drinking water samples throughout the aforementioned school.

No lead concentrations exceeding 15 µg/l [ppb] were identified in drinking water outlets or food preparation sinks.

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At very high levels, lead can even



cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

For More Information

A copy of the test results is available at the Downtown Middle School central office for inspection by the public, including students, teachers, other school personnel, and parents. The results are also available on the North Star Academy website at <https://northstar.uncommonschoools.org/lead-results/>. For more information about water quality in the North Star Academy schools, contact Kamal Johnson, Senior Manager, Facilities Management Team, at Kamal.Johnson@uncommonschoools.org.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,



Chris Esposito, LSRP
Vice President

Enclosures: Full Analytical Data Table

Table 1

**Downtown Middle School
18 Washington Street
Newark, NJ 07102**

Lead in Drinking Water Sampling Results

Sample ID:	NJ Drinking Water Quality Standards (NJAC 7:10 9/18) (µg/L)	GF-WF-1	GF-BF-1	F1-KS-R110	F2-WFT-1	F2-WFS-1	F2-BF-1	F3-KS-R314	F3-WC-R314	F4-KS-1	F4-WC-1
Lab ID:	24G1496-01	24G1496-02	24G1496-03	24G1496-04	24G1496-05	24G1496-06	24G1496-07	24G1496-08	24G1496-09	24G1496-10	24G1496-10
Date Sampled:	7/19/2024	7/19/2024	7/19/2024	7/19/2024	7/19/2024	7/19/2024	7/19/2024	7/19/2024	7/19/2024	7/19/2024	7/19/2024
Analyte											
Lead	15	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0

RL - Reporting Limit
µg/L - Microgram Per Liter
<2.0 - Indicates no detection above the RL